

## SAMOA WATER AUTHORITY

NON -REVENUE WATER (NRW) GUIDELINE



### Statement for the PWWC theme:

#### > Smart Island Water:

As islanders we have come a long way in planning and implementing water system projects that exists today. Most of these utilities have aged and exceeded its usefulness and at least 40yrs old or more in some islands including Samoa. Now we are faced with a new kind of challenge of water loss and NRW rates that keeps increasing every year.

How can we be smart about it? What methods and technologies that exists today that can be used to counter this new problem in the island?



## Content of the Guideline





03 Systems Assessments



05 Control of NRW

06 Water loss and Leak Detection

107 Integrated Approach to NRW management

08 Case Study

09 Sustainable monitoring of NRW



### 2. Definition of NRW

➤ Volume of water that is distributed in the water supply network but does not yield returns.

NRW is the total production of treated water minus the total billed metered consumption.

...Malcolm Farley (NRW Handbook)

NRW = Production Volume – Billed Consumption Assumption:

- ➤ System input has been corrected of any errors
- ➤ Billed metered consumption period for customers billing records are consistent with the system input volume period.

		Billed Authorised Consumption	Billed Metered Consumption Billed Unmetered Consumption	Revenue Water					
Consum	Authorised Consumption	Unbilled							
	Consumption	Authorised Consumption	Unbilled Unmetered Consumption						
		Commercial	Unauthorised Consumption						
System Input Volume	Water Losses	Losses	Customer Meter Inaccuracies and Data Handling Erros	Non-Revenue					
			Leakage on Transmission and Distribution Mains	Water					
		Physical Losses	Leakage and Overflows from the Utilities Storage Tanks						
			Leakage on Service Connections up to the Customer Meter						



- 3. System Assessments
  - System assessments are carried out by various ways including Water balance exercises that are carried out periodically to access the volumes that are produced to match up with monthly consumptions per DMAs.
  - SWA to conduct this exercise on a quarterly basis to evaluate and audit water that is lost through the network or from big transmission pipes.
  - Billing accuracies and meter reading analysis to assess the accuracy of the information that will be used to calculate NRW
  - Accurate systems mapping and DMA isolations to be corrected
  - System information

#### SWA NRW HISTORICAL INFORMATION

			Unit	Avera	ge Jul-:	.7 Aug	g-17	Sep-17	Oct-17	Nov-17	Dec-17	Jan-18	Feb-18	Mar-18	Apr-18	May-18	Jun-18	Average
				2016,	17													2017/18
Malololelei			%	49%			5%	48%	53%	59%	60%	62%	54%	63%	43%	68%	48%	56%
Alaoa			%	569	649	6 55	5%	50%	56%	49%	54%	46%	42%	51%	53%	55%	44%	52%
Fuluasou			%	529	<mark>6 51</mark> 9	6 42	.%	50%	52%	47%	49%	47%	43%	63%	55%	56%	44%	50%
Weighted average - a	II 3 service a	areas	%	54%	599	6 48	8%	50%	54%	48%	52%	47%	43%	58%	53%	56%	44%	51%
Malololelei			L/conn/	'd <b>1,8</b> 7	3,02	2 1,7	779	1,577	1,731	2,138	2,229	2,300	2,319	2,218	1,452	2,445	1,631	2,070
Alaoa			L/conn/	'd <b>2,9</b> 6	3,73	6 3,1	.51	2,840	3,139	2,360	2,624	2,131	1,975	2,548	2,514	2,643	2,149	2,651
Fuluasou			L/conn/	'd 2,07	1,79	9 1,5	25	1,814	1,852	1,611	1,624	1,635	1,624	2,602	2,216	2,050	1,455	1,817
FY 2017/18 Target			L/conn/	/d 2,90	0													2,650
Weighted average - a	Weighted average - all 3 service areas		L/conn/	'd <b>2,4</b> 9	2,80	5 2,3	49	2,324	2,500	1,995	2,139	1,904	1,822	2,560	2,310	2,342	1,799	2,242
	Unit	Jul-17	Aug-17	Sep-17	Oct-17	No	v-17	Dec	:-17	Jan-18	Feb-1	8 M	ar-18	Apr-18	May	-18	Jun-18	Average
																		2017/18
Vailele WTP	%	40%	17%	47%	55%	4	1%	39	9%	43%	17%	. 3	32%	16%	329	%	21%	33%
Fagalii WTP	%	78%	73%	40%	60%	$\epsilon$	4%	55	5%	57%	-3%	(1)	39%	30%	499	%	27%	48%
Vailima WTP	%	56%	51%	15%	51%	2	4%	47	7%	41%	31%		51%	37%	549	%	27%	40%
Vailele WTP	L/conn/d	1,075	388	1,527	2,606	1,	455	1,2	230	1,199	440		711	364	71	7	444	1,013
Fagalii WTP	L/conn/d	5,047	4,487	1,716	1,689	1,	947	1,4	113	1,314	-48	(	550	527	74	9	446	1,661
Vailima WTP	L/conn/d	3,168	2,916	762	2,776	ç	67	2,3	317	1,956	1,504	1 2	,382	1,646	2,37	70	1,169	1,994
										_								

Duval NDW Cummon	Average	Jul-17	Aug-17	Sep-17	Oct-17	Nov-17	Dec-17	Jan-18	Feb-18	Mar-18	Apr-18	May-18	Jun-18	Average
Rural NRW Summary	2016/17													2017/18
Fuluasou EU WTP & Supplementary Boreholes	46%	49%	38%	41%	40%	55%	58%	72%	47%	58%	57%	56%	51%	52%
Lefaga	55%	57%	69%	67%	47%	48%	58%	40%	51%	64%	62%	50%	69%	57%
Tafitoala & Tiavi	65%	59%	47%	54%	74%	65%	58%	32%	40%	56%	53%	49%	41%	52%
Togotogiga TP	46%	58%	52%	64%	50%	54%	66%	54%	61%	66%	64%	68%	32%	58%
Vaovai BH, Piu & Matatufu BH	54%	63%	60%	63%	54%	53%	62%	46%	49%	61%	62%	64%	55%	58%
Lepa	21%	-5%	12%	-3%	-14%	8%	14%	-56%	1%	-25%	14%	-8%	13%	-4%
Lake Lano														
Lalomanu	44%	52%	43%	47%	55%	47%	49%	51%	36%	53%	31%	30%	44%	45%
Satitoa	66%	73%	70%	44%	56%	66%	71%	54%	70%	67%	73%	61%	62%	64%
Faleapuna	59%	53%	45%	46%	42%	47%	46%	31%	49%	64%	62%	47%	50%	48%
Overal Rural NRW	51%	52%	46%	47%	46%	54%	58%	67%	47%	59%	58%	55%	53%	54%

	Average	Jun-17	Jul-17	Aug-17	Sep-17	Oct-17	Nov-17	Dec-17	Jan-18	Feb-18	Mar-18	Apr-18	May-18	Jun-18	Average
	2016/17														2017/18
Faleata (Palauli)		55%	52%	55%	53%	44%	60%	53%	48%	59%	65%	61%	49%	50%	54%
Iva		21%	58%	48%	41%	48%	68%	64%	47%	61%	73%	12%	7%	56%	48%
Lalomalava				4%	7%	44%	5%	36%	24%	55%	76%	44%	66%	81%	40%
Sapapalii		60%	60%	61%	43%	40%	45%	37%	42%	58%	39%	78%	81%	73%	55%
Logoipulotu		75%	84%	70%	68%	69%	76%	81%	60%	72%	82%	76%	75%	79%	74%
Faga 1		43%	52%	48%	24%	31%	43%	34%	14%	58%	62%	85%	88%	86%	52%
Lano & Puapua		39%	48%	51%	32%	31%	49%	35%	25%	38%	34%	41%	38%	8%	36%
Saleaula		34%	55%	47%	61%	51%	59%	56%	51%	36%	52%	12%	6%	21%	42%
Safotu		41%	50%	30%	26%	23%	29%	15%	9%	22%	26%	30%	27%	8%	25%
Matavai 1		29%	55%	59%	49%	47%	50%	49%	23%	35%	14%	15%	23%	38%	38%
Matavai 2		64%	72%	66%	62%	45%	68%	61%	48%	40%	33%	11%	15%	2%	44%
Letui		78%	70%	69%	66%	66%	64%	65%	65%	71%	86%	77%	74%	63%	70%
Asau		48%	51%	48%	48%	33%	68%	69%	77%	75%	71%	66%	48%	45%	58%
Auala		46%	22%	57%	58%	49%	59%	53%	56%	61%	50%	70%	72%	65%	56%
Sataua		67%	59%	76%	71%	68%	28%	69%	51%	49%	73%	56%	61%	42%	59%
Falealupo		33%	6%	12%	15%	23%	9%	28%	15%	19%	49%	29%	19%	38%	22%
Neiafu		50%	21%	33%	21%	10%	6%	34%	24%	50%	23%	43%	54%	50%	31%
Samata & Fogatuli		55%	43%	55%	46%	44%	57%	69%	57%	42%	63%	32%	55%	46%	51%
Fogasavaii & Sagone		44%	45%	47%	46%	43%	35%	40%	35%	34%	58%	25%	26%	21%	38%
Taga		61%	50%	50%	54%	51%	57%	58%	43%	48%	52%	48%	62%	50%	52%
Overall Savaii NRW	58%	53%	51%	54%	51%	44%	53%	53%	44%	53%	60%	54%	48%	45%	51%

## 4. NRW Target Setting

01

Target setting and preparation for SWA will be based on detailed analysis of all its independent systems.

03

Mapping is the key components to be established and ensure all system assets are consolidated and network pipes are in accurate locations

05

Calculate a target that is achievable within specified timeframes

02

Each systems are unique and has to be evaluated and assessed carefully due to its age and considered as new, fairly new, partially new, and old as in more that 30years.

04

System meters for all DMAs should be updated and upgraded. All domestic meters replaced and within seven year replacement period



SWA will control NRW developing KPIs for each component of the system.

**Such components are:** 

Accurate meter reading of target consumption and flow allowances


Line replacement planning and targets

1

2


3

Pressure management (1 – 4)bar pressure. By using control valves and appropriate pipe sizing



Ensure instrumentation and equipment calibrations for ultrasonic meters and leak detection devices





## 6. Water Loss and Leakage Detection

By utilizing the new SCADA system to record and collect accurate information

Utilizing smart meter technology

Using ultrasonic meters for water balance

Using leak detection equipment (ground mic, listening sticks, correlators, etc




# 7. Integrated Approach in NRW Management


- Develop Strategic approach and action plans with other department. Includes, O&M Divisions, Billing Division, Technical Planning & Asset Management Division, Customer Service Division and I.CT Division. Also awareness programs with the customers.
- > Ensure that everyone is aware of NWR % monthly targets
- > Work towards the same targets and update all systems


## 8. NRW Case Study — "ALAOA WATER SUPPLY SYSTEM"

- Alaoa Water supply system supplies the Apia township in the urban central of Upolu Island, Samoa
- > It caters for about
- Can produce at an average 200,000-400,000cm per month at and average flow of 150l/s
- Alaoa Supply is divided into 12 DMAs all logged and data loggers
- Most leakages occur in the central Apia area,
- ➤ Study period from 2013 2019
- > NRW% in 2013 = 74% (due to heavy leakages in the network)
- ➤ NRW% in 2019 = 36% (reduction due to Target setting, strategic planning, meter replacement, pipeline replacements, leak detection and technology improvement with integrated efforts)

### Alaoa Water Supply Scheme Logging Points







### Alaoa WTP Water Balance

m<sup>3</sup>/month

Water	Balance Item	Sep-2014	Average Jul thr Nov-2017			Jun-2	019		- 80				
red	1. Billed Authorized	RW 148,734	RW 206,205	1.1 Billed Metered Con	sumption (I	ncluding w	ater export	ed)		RW 229,978			
Authorized	Consumption		(726)	1.2 Billed Unmetered C	.2 Billed Unmetered Consumption (Flat Rate)								
Con	2. Unbilled Authorized		(0)	2.1 Unbilled Metered C	.1 Unbilled Metered Consumption								
	Consumption		(77)	2.2 Unbilled Unmetered	d Consumpt	tion			(77)				
	3. Apparent		(1,237)	sumption (III	egal Conne	ction, etc.)		(0)					
	Losses		(19,400)	3.2 Metering Inaccurac	3.2 Metering Inaccuracies (4,600)								
		NRW	27,089		4.1 Leakage on Transmission and Distribution Mains up to DMA bulk meters except for DMA2, 3, and 4 35,322								
		318,754	7,256	4.2 Leakage and Over	7,256	147,910							
Water				4.3 Leakage on Distribution in	DMA1	7,244	DMA7	7,524					
33	4. Real			DMA and	DMA2	13,919	DMA8	1,725	105,332				
	Losses		243,190	Service Connections	DMA3	8,475	DMA9	-10					
				up to point of Customer meter	DMA4	1,056	DMA10	232					
			[NRW]		DMA5	34,916	DMA11	1,781					
			[277,535]	Item 1,2, 2.1, 2.2, 3.1, 3.2	DMA6	26,816	DMA12	1,654					
Wat	Water Distrubuted 467,488 483,740 377,888												

### Alaoa WTP Water Balance

Percentage %

Water I	Balance Item	Sep-2014	Average Jul thr Nov- 2017			Jun-2	2019					
zed otion	1. Billed Authorized	RW 31.8%	RW <b>42.6</b> %	1.1 Billed Metered Cons	Billed Metered Consumption (Including water exported)							
Authorized	Consumption		(0.2%)	1.2 Billed Unmetered C	2 Billed Unmetered Consumption (Flat Rate)							
Con	2. Unbilled Authorized		(0.0%)	2.1 Unbilled Metered Co	2.1 Unbilled Metered Consumption							
	Consumption		(0.0%)	2.2 Unbilled Unmetered	Consumpti	on			(0.0%)			
	3. Apparent		(0.3%)	3.1 Unauthorized Const	umption (Ille	gal Connec	ction, etc.)		(0.0%)			
	Losses		(4.0%)	3.2 Metering Inaccuraci	3.2 Metering Inaccuracies							
		NRW	5.6%		1 Leakage on Transmission and Distribution Mains up to DMA bulk meters except for DMA2, 3, and 4  9.3%							
		68.2%	1.5%	4.2 Leakage and Overflo	.2 Leakage and Overflows at Utility' storage Tanks							
Water Losses				4.3 Leakage on Distribution in	DMA1	1.9%	DMA7	2.0%				
2 کا	4. Real			DMA and	DMA2	3.7%	DMA8	0.5%				
	Losses		50.3%	Service Connections	DMA3	2.2%	DMA9	0.0%	27.9%			
				up to point of Customer meter	DMA4	0.3%	DMA10	0.1%				
			[NRW]		DMA5	9.2%	DMA11	0.5%				
			[57.4%]	Item 1,2, 2.1, 2.2, 3.1, 3.2	DMA6	7.1%	DMA12	0.4%				
Wa	Water Distrubuted 100.0% 100.0% 100.0%											

### Summary 1: DMA loss (I/s)

	Number of Pipelines	Length	Leakage	Fixed or Replaced	Remaining Leakage
Transmission	3	5,850 m	17.0 L/s	12.0 L/s	5.0 L/s
DMA1	16	6,440 m	4.1 L/s		4.1 L/s
DMA2	15	7,315 m	7.1 L/s	3.0 L/s	4.2 L/s
				2.2 L/s	2.0 L/s
DMA3	10	5,586 m	3.9 L/s		3.9 L/s
				2.2 L/s	1.8 L/s
DMA4	6	2,632 m	2.1 L/s		2.1 L/s
DMA5	31	9,600 m	33.2 L/s	12.6 L/s	20.6 L/s
DMA6	20	11,095 m	28.2 L/s	4.0 L/s	24.2 L/s
DMA7	7	2,362 m	4.2 L/s		4.2 L/s
DMA8	6	1,361 m	0.8 L/s		0.8 L/s
DMA9	5	1,467 m	1.8 L/s		1.8 L/s
DMA10	1	750 m	0.4 L/s		0.4 L/s
DMA11	1	1,185 m	0.9 L/s		0.9 L/s
DMA12	29	9,271 m	1.4 L/s		1.4 L/s
Total	150	64,914 m	105.2 L/s	31.6 L/s	73.6 L/s
				35.9 L/s	69.3 L/s

### Summary 2: Priority Works

DMA#	Section	Pipe	Diameter	_	Leakage	Yearly	Leakage Cost	Replacement	Payback	Priority
		Material	(mm)	(m)	(L/s)	Leakage	in one year	Cost (Tala)	Period	
						(m3/Year)	(Tala)		(Year)	
								only indicative		
DMA4	Submain Maagao	PVC	50	530	1.02	32,167	5,854	130,380	22.3	11
	Matautu StSubmain 1	PVC	100	100	0.78	24,598	4,477	37,300	8.3	2
	Matautu StSubmain 2	PVC	100	100	0.92	29,013	5,280	37,300	7.1	1
DMA5	Beach Rd. (Clock Tower - Ifiifi St.)	PVC	150	240	2.40	75,686	13,775	131,040	9.5	4
DMAS	Beach Rd. (Apia EFKS Church-After Bridge Intersection)	PVC	150	330	1.26	39,735	7,232	180,180	24.9	13
	Vaialavini Rd	PVC	100	500	1.39	43,835	7,978	186,500	23.4	12
	Fugalei St. (1/3)	PVC	150	400	2.00	63,072	11,479	218,400	19.0	10
	Fugalei St. (2/3)	PVC	150	400	2.50	78,840	14,349	218,400	15.2	9
	Fugalei St. (3/3)	PVC	150	400	1.50	47,304	8,609	218,400	25.4	14
DMA6	Saleufi St. (2/2)	PVC	150	313	3.00	94,608	17,219	170,898	9.9	5
	Mulinuu St. (1/2)	PVC	150	450	3.96	124,883	22,729	245,700	10.8	6
	Mulinuu St. (2/2)	PVC	150	450	1.55	48,881	8,896	245,700	27.6	15
	Savalalo Rd. (Saleufi StFugalei St.)	PVC	100	228	1.70	53,611	9,757	85,044	8.7	3
DMA7	Valve C to Valve D	PVC	100	300	1.52	47,935	8,724	111,900	12.8	8
DIVIA /	Valve B to Main	PVC	50	366	1.23	38,789	7,060	90,036	12.8	7



- > Continuous reporting
- ➤ Updated SOPs
- > Handover documents
- Improved technology (SCADA, Mapping, Smart metering, leak detection, GPS and data logging)
- >Climate resilient design and planning

## THANK YOU FROM

